

Project for Community Development Block Grant

Applicant: City of Hamilton
Wastewater treatment and collector system improvements
CDBG Project No. 03-PF-320

Contact Person: Robert E. Hosack

Address: Hosack Community Planning and Development
209 East Tenth St.
Chanute, KS 66720

Phone: 316-431-9547

Sent to the Kansas Geological Survey for environmental review.

Agency Review Comments:

Any short-term adverse impacts during construction should be offset by the long-term benefits of the improvements to the wastewater treatment and collector system

Recommended Action:

- ☒ Clearance of project should be granted
- ☐ Clearance of project should not be granted
- ☐ Clearance of project should be delayed until the issues or questions have been clarified
- ☐ Clearance of project should not be delayed, but the applicant (in the application) should address or clarify the questions or concerns indicated above

Donald O. Whittemore
Reviewer's Name

Geohydrology Section, Kansas Geological Survey
Division/Agency

5/14/03
Date

Donald O. Whittemore
Reviewer's Signature



Community Planning and Development Services

209 East Tenth Street — Chanute, Kansas 66720 — (316) 431-9547

April 28, 2003

Mr. Donald Whittemore, Senior Scientist
Kansas Geological Survey
The University of Kansas
1930 Constant Avenue, Campus West
Lawrence, Kansas 66047-3726

**Re: City of Hamilton, Kansas
CDBG Environmental Assessment
CDBG Project Number 03-PF-320**

Dear Mr. Whittemore:

The City of Hamilton, Kansas, located in Greenwood County, was recently awarded Community Development Block Grant (CDBG) funds to construct improvements to the City's wastewater treatment and collector system. As a part of the CDBG environmental review process, comments on this proposed project by your agency are hereby requested. In order for your agency's comments to be considered, they must be received in writing at the **letterhead address** above on or before **Thursday, May 29, 2003**. If your agency does not respond by the specified date, it will be considered as a "no comment" on the project.


In order to comply with a Kansas Department of Health and Environment Mandated Schedule of Compliance, the proposed wastewater treatment and collector system improvements will consist of constructing a third cell at the existing 2-cell wastewater treatment lagoon; adjusting and resealing 9 manholes; removing 12 obstructions in the 8-inch sewer mains; replacing 261 linear feet of 10-inch sewer main; and repairing identified sewer main leaks. Enclosed for your review are 3 project location maps.


Technical information about this project may be obtained by contacting Shoeb Uddin, P.E., CP Engineers and Land Surveyors, Inc., Topeka, Kansas, at (785) 267-5071. If you should have any other questions, please do not hesitate to contact me at (620) 431-9547.

Sincerely,


Robert E. Hosack
Hamilton CDBG Administrator

Enclosures





WASTEWATER LAGOONS
CITY OF HAMILTON, KANSAS



SANITARY SEWER MAP CITY OF HAMILTON, KANSAS

-  Manhole Repair
-  Sewer Line Repair