

KANSAS GEOLOGICAL SURVEY

The University of Kansas
1930 Constant Ave
Lawrence KS 66047-3726
phone 785-864-3965
fax 785-864-5317
www.kgs.ku.edu

September 25, 2006

Ms. Becky Voorhies
Planning and Development Consultant
Southeast Kansas Regional Planning Commission
P.O. Box 664
Chanute, KS 66720-0664


Dear Ms. Voorhies:

I received your inquiry to the Kansas Geological Survey seeking input on "Environmental Assessment Comments" for improvements to the water lines for the City of Parker, Kansas. The project consists of a number of upgrades to the water line system with the distribution of the upgrades shown on the small map attached with your letter. This includes upgrade of 4,160' of 6" PVC, 9,240' of 4" PVC, 3,900' of 2" PVC, and 5,840' of 1" PVC distribution pipe.

It is my understanding that this review is necessary for the City of Parker to be considered for a grant for waterline improvements from the Kansas Department of Commerce Small Cities Community Development Block Grant Program. I do not recognize any specific problems with your request based on the information you have provided with your letter. Therefore, the Kansas Geological Survey provides the necessary clearance from our agency for your project and I have signed the form requesting environmental assessment comments.

The above discussion represents our best assessment based on the information that the Kansas Geological Survey has about this locality and/or proposed project at the time of this writing. Other geologic conditions, not discussed herein, or for which the Kansas Geological Survey has no knowledge, may affect the viability or safe operation of this facility or property. The information provided in this letter is from regional or countywide studies and should not be used as a substitute for detailed site characterization by a licensed geologist or engineer. It is the responsibility of the applicant to provide any required site characterizations.

Sincerely,



Lawrence L. Brady
Senior Scientist

Enc.

Request for Environmental Assessment Comments

REPLY REQUESTED BY: 10/4/06

TO: Larry Brady Kansas Geological Survey University of Kansas 1930 Constant Avenue, Campus West Lawrence, KS 66047 (Please indicate any change in address or personnel)	GRANT NUMBER AND PROGRAM: Kansas Department of Commerce and Housing Small Cities Community Development Block Grant Program
APPLICANT NAME AND ADDRESS: City of Parker 310 W. Main Parker, KS 66072	RETURN TO: Becky Voorhies, Planning & Development Consultant Southeast Kansas Regional Planning Commission P.O. Box 664 Chanute, KS 66720-0664
PROGRAM ACTIVITY/PROJECT NAME: Water line Improvement	LOCATION: Parker, Kansas Linn County

PROGRAM ACTIVITY/DESCRIPTION: The proposed project will be the replacement of asbestos cement and steel main line piping with 4,160 LF of 6" PVC, 9,240 LF of 4" PVC, 3,900 LF of 2" PVC and 5,840 LF of 1" PVC. This project will upgrade the main line size to improve distribution and will reduce water loss and operation and maintenance.

REVIEW AGENCY COMMENTS:

No Comment _____ Project Approval _____ Other ☒ (Explain Below)

See comment in enclosed letter

SIGNATURE: <i>Lawrence L Brady</i>	TITLE: <i>Senior Scientist Kansas Geol. Survey</i>	DATE: <i>9/25/06</i>
---------------------------------------	---	-------------------------

