

March 6, 2007

Peter W. Earles
Earles Engineering & Inspection, Inc.
115 W. Iron Ave.
Salina, Kansas 67401

*Mailed to
Liberal address.*

Dear Mr. Earles,

I have reviewed the proposed project to replace the water well for the City of Kismet. Based on the documents attached to your request, it does not appear that there are any potential geologic hazards worth noting that might impact this project. Note that the required well depth may be shallower than you have indicated based on the information we have available at the Kansas Geological Survey.

The above discussion represents our best assessment based on the information that the Kansas Geological Survey has about this locality and/or proposed project at the time of this writing. Other geologic conditions, not discussed herein, or for which the Kansas Geological Survey has no knowledge, may affect the viability or safe operation of this facility or property. The information provided in this letter is from regional or countywide studies and should not be used as a substitute for detailed site characterization by a licensed geologist or engineer. It is the responsibility of the applicant to provide any required site characterizations.

If you have any questions please do not hesitate to contact me at my office (785 – 864-2068).

Sincerely yours,


P. Allen Macfarlane

Earles Engineering & Inspection, Inc.

Civil & Structural Engineers · Construction Inspectors

115 W. Iron Ave. - Salina, KS 67401

Phone: 785) 309-1060

Fax: 785) 309-1061

211 N. Kansas Ave. - Liberal, KS 67901

Phone: 620) 626-8912

Fax: 620) 626-5408

January 18, 2007

Kansas Dept. of Wildlife & Parks
Environmental Services Section
512 SE 25th Avenue
Pratt, KS 67124-8174

U.S. Department of Agriculture
Natural Resources Conservation Service
760 South Broadway
Salina, KS 67401-4642

Kansas State Historical Society
State Historic Preservation Office
6425 SW 6th Avenue
Topeka, KS 66615-1099

Kansas Corporation Commission
Conservation Division
130 S. Market, Room 2078
Wichita, KS 67202-3802

Kansas Water Office
901 S. Kansas Ave.
Topeka, KS 66612-1249

State Conservation Commission
109 SW 9th St., Suite 500
Topeka, KS 66612-1299

Kansas Dept. of Health & Environment
Donna Fisher, Division of Environment
1000 SW Jackson St., Suite 400
Topeka, KS 66612-1367

Kansas Biological Survey
University of Kansas
2101 Constant Ave., Higuchi Hall
Lawrence, KS 66047-3759

Kansas Dept. of Agriculture
Division of Water Resources
109 SW 9th St., 2nd Floor
Topeka, KS 66612-1283

US Department of the Interior
Fish & Wildlife Service
315 Houston, Suite E
Manhattan, KS 66502-6172

Kansas Geological Survey
University of Kansas
1930 Constant Ave., Campus West
Lawrence, KS 66047

US Army Corps of Engineers
Kansas City District
700 Federal Building – 601 E. 12th St.
Kansas City, MO 64106-2896

Re: City of Kismet, Kansas
Kansas Public Water Supply Loan Fund
Project No. 06-42

To Whom It May Concern:

The City of Kismet is preparing an application to the Kansas Department of Health & Environment for a loan from the Kansas Public Water Supply Loan Fund for the above-referenced project.


The project will consist of drilling a new well 65 feet from the existing collapsed well. A new well house and chlorine room will be constructed over the new well. The well location is as follows:

NE/4 of the NW/4 of the SW/4 of Section 4, Township 33 South, Range 31 West, Seward County, Kansas.

The Well is 2,153 feet north and 4,375 feet west of the southeast corner of said section. The proposed depth is 479 feet.

I would appreciate your review of the project description and location, and any comments you may have within 30 days. A project review form is enclosed for your use. Please call myself at 620) 626-8912 if you have any questions

EARLES ENGINEERING & INSPECTION, INC.

A handwritten signature in black ink, appearing to read 'Peter W. Earles', written in a cursive style.

Peter W. Earles, P.E.
CEO

Enclosure

Change in PD,
File No 17521

